

**STATE OF INDIANA
DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

PUBLIC NOTICE NO. 2000-2-A-RD-P

DATE OF NOTICE: February 14, 2000

DATE RESPONSE DUE: March 15, 2000

The Office of Water Quality proposes the following permit actions listed below:

NPDES PERMIT PROPOSED/MINOR-RENEWAL

BEST WESTERN ANGOLA INN WWTP, approximately 2 miles west of Angola, Indiana, NPDES Permit No. IN0042196. The above-named applicant has applied for renewal of their NPDES permit to discharge 0.017 million gallons per day of treated sanitary wastewater into an unnamed ditch to Mud Lake, which lies within the Great Lakes Drainage Basin located in STEUBEN COUNTY. The applicant operates a minor semi-public wastewater treatment plant. Proposed effluent parameters to be limited and/or monitored at Outfall No.001: flow, CBOD5, total suspended solids, ammonia-nitrogen, phosphorus, pH, dissolved oxygen and total residual chlorine. Permit Writer: Mr. Gale Ferris at 317/232-8739. Published in the </Herald Republican.

CITY OF CHARLESTOWN WWTP, 229 Charlestown Landing Road, Charlestown, Indiana, NPDES Permit No. IN0020508. The above-named applicant has applied for renewal of their NPDES permit to discharge 0.69 million gallons per day of treated sanitary wastewater into the Ohio River located in CLARK COUNTY. The applicant operates a minor municipal wastewater treatment plant. Proposed effluent parameters to be limited and/or monitored at Outfall No. 001: flow, CBOD5, total suspended solids, pH and total residual chlorine. Permit Writer: Jay Hanco at 317/233-0470. Published in the Evening News.

CHRISNEY WWTP, 770 East, County Road 900 North, Chrisney, Indiana, NPDES Permit No. IN0039306. The above-named applicant has applied for renewal of their NPDES permit to discharge 0.07 to 0.14 million gallons per day of treated sanitary wastewater into an unnamed tributary to the East Fork of Little Pigeon Creek located in SPENCER COUNTY. The applicant operates a minor municipal wastewater treatment plant. Proposed effluent parameters to be limited and/or monitored at Outfall No. 001: flow, CBOD5, total suspended solids, ammonia-nitrogen, pH, dissolved oxygen and total residual chlorine. Permit Writer: Jay Hanco at 317/233-0470. Published in the Spencer County Journal.

CRESWOOD MOBILE HOME PARK WWTP, west side of Lake McCoy approximately 3 ½ miles east of Greensburg, Indiana, NPDES Permit No. IN0043095. The above-named applicant has applied for renewal of their NPDES permit to discharge 0.0225 million gallons per day of treated sanitary wastewater into Cobbs Fork located in DECATUR COUNTY. The applicant operates a minor semi-public wastewater treatment plant. Proposed effluent parameters to be limited and/or monitored at Outfall No. 001: flow, CBOD5, total suspended solids, ammonia-nitrogen, pH, dissolved oxygen and total residual chlorine. Permit Writer: Mr. Gale Ferris at 317/232-8739. Published in the Greensburg Daily News..

DEVON WOODS UTILITIES WWTP, off of an unnamed lane between 1302 and 1304 Arundel Drive in Kokomo, Indiana NPDES Permit No. IN0044652. The above-named applicant has applied for renewal of their NPDES permit to discharge 0.027 million gallons per day of treated sanitary wastewater into Wildcat Creek located in HOWARD COUNTY. The applicant operates a minor semi-public wastewater treatment facility. Proposed effluent parameters to be limited and/or monitored at Outfall No. 001: flow, CBOD5, total suspended solids, total residual chlorine and pH. Permit Writer: Jerry Dittmer at 317/233-0469. Published in the Kokomo Tribune.

DRIFTSIDE MOBILE HOME PARK, 13500 North U.S. 31, Edinburgh, Indiana, NPDES Permit No. IN0031879. The above-named applicant has applied for renewal of their NPDES permit to discharge 0.0354 million gallons per day of treated sanitary wastewater into Driftwood River located in BARTHOLOMEW COUNTY. The applicant operates a semi-public wastewater treatment plant. Proposed effluent parameters to be limited and/or monitored at Outfall No. 001: flow, CBOD5, total suspended solids, pH and total residual chlorine. Permit Writer: Roger Rylatt at 317/232-8619. Published in The Republic.

EASTERN DISTRICT ELEMENTARY AND HIGH SCHOOL WWTP, near the intersection of State Road 54 and State Road 43, Greene County, Indiana, NPDES Permit No. IN0031470. The above-named applicant has applied for renewal of their NPDES permit to discharge 0.02 million gallons per day of treated sanitary wastewater into an unnamed ravine to Beech Creek to Richland Creek located in GREENE COUNTY. The applicant operates a minor semi-public wastewater treatment plant. Proposed effluent parameters to be limited and/or monitored at Outfall No. 001: flow, CBOD5, total suspended solids, ammonia-nitrogen, pH, dissolved oxygen and total residual chlorine. Permit Writer: Mr. Gale Ferris at 317/232-8739. Published in the Linton Daily Citizen and The Evening World.

NPDES PERMIT PROPOSED/MINOR REVOCATION & REISSUANCE

MERRILLVILLE COMMUNITY SCHOOL CORP/JOHN WOOD ELEMENTARY SCHOOL WWTP, 6100 East 73rd Avenue, Merrillville, Indiana, NPDES Permit No. IN0031771. The above-named applicant has applied for modification of their NPDES permit to discharge 0.006525 million gallons per day of treated sanitary wastewater into an unnamed tributary to the Deep River located in LAKE COUNTY. The applicant operates a semi-public wastewater treatment plant. This permit is being revoked and reissued, due to the recent revisions to the permittee's wastewater treatment plant, the following parameters are to be limited and/or monitored at Outfall No. 001: flow, CBOD5, total suspended solids, ammonia-nitrogen, pH, dissolved oxygen and E.coli. Permit Writer: Jay Hanco at 317/233-0470. Published in the Post Tribune and The Times.

PRAIRIE UTILITIES, INC, WWTP, at the intersection of U.S. 31 and County Road 600 near Sharpsville, Indiana, NPDES Permit No. IN0041866. The above-named applicant has applied for modification of their NPDES permit to discharge 0.055 million gallons per day of treated sanitary wastewater into Kelly West Ditch and then to an unnamed pond less than 2 miles downstream located in TIPTON COUNTY. The applicant operates a minor semi-public wastewater treatment plant. This permit is being revoked and reissued, due to the recent revisions to the permittee's wastewater treatment plant, the following parameters are to be limited and/or monitored at the discharge from Outfall No. 001: flow, CBOD5, total suspended solids, ammonia-nitrogen, phosphorus, pH, dissolved oxygen and total residual chlorine. Permit Writer: Mr. Gale Ferris at 317/232-8739. Published in The Tipton County Tribune.